



CERTIFICATIONS

FloorScore®

SCS Global Services does hereby certify that an independent assessment has been conducted on behalf of:

Ceramica del Conca S.p.a

Via Croce, 8 47832, San Clemente (RN), Italy

For the following product(s):

Ceramic Flooring:

Gres Porcellanato Del Conca, Pastorelli, Featano, Optimum
(Maximum thickness: 30.0mm)

The product(s) meet(s) all of the necessary qualifications to be certified for the following claim(s):

FloorScore®

Indoor Air Quality Certified to SCS-105 Version 4.2 – 2023

Conforms to the CDPH/EHLB Standard Method v1.2-2017 (California Section 01350), effective April 1, 2017, for the school classroom and private office parameters when modeled as Flooring.

Measured Concentration of Total Volatile Organic Compounds (TVOC): Less than/equal to 0.5 mg/m3 (in compliance with CDPH/EHLB Standard Method v1.2-2017)

Registration # SCS-FS-06343

Valid from: February 01, 2025 to January 31, 2026

SCS Global Services is currently the only certification body approved by the Resilient Floor Covering Institute (RFCI) to provide FloorScore® product certification; certified products are only listed on the SCS Green Products Guide, <http://www.scsglobalservices.com/certified-green-products-guide>.



A handwritten signature in black ink.

Diana Kirsanova Phillips, Chief Assurance Officer,
SCS Global Services